

# WVU ENVIRONMENTAL HEALTH AND SAFETY DINING HALL AUDIT REPORT

## DINING HALL LOCATION:

Café Evansdale

## INSPECTION TYPE:

Routine

## DATE OF INSPECTION:

5/19/22

## NUMBER OF VIOLATIONS:

Priority:	0
Priority Foundation:	0
Core:	1
Total:	1

## VIOLATION #1

Criticality: Core

Corrected During Visit? Yes  No

### OBSERVATION:

4-501.11- GOOD REPAIR, PROPER ADJUSTMENT- The middle walk-in freezer downstairs with the new door has ice build-up at the top of the door and on the floor at the bottom of the door.

### CORRECTION NEEDED:

Make sure the seal on the door is working properly to prevent an air leak and ice build-up. Facilities was on-site to turn off the freezer until repairs are made.

## VIOLATION #2

Criticality:

Corrected During Visit? Yes  No

### OBSERVATION:

### CORRECTION NEEDED: